

**July 29, 2016 Daily Update provided by Fred Whistle, AV Water**

- 1. Deficiency Report:** No update See below
- 2. Deficiency Repair:** No update See below
- 3. System Map:** No update See below
- 4. Water conservation Measures:** A media release was issued by San Juan County in our behalf urging customers to conserve water over the weekend to allow flushing to begin Monday morning.
- 5. Weekly Updates:** Weekly update was sent out this morning to all media. Customers to be followed up by mail.
- 6. Daily Updates:** Daily Updates have been provided since June 26, 2016.

Today's information not included in other Order numbers:

- A. Boil Advisory still in effect.
  - B. System is functioning. Mesa Heights tanks are about 95% full and Star Heights tanks are about 100% full. The permanent pump station continues to pump at full capacity. The treatment plant has been shut down since 8am July 14.
  - C. A flushing program has been designed by Doug Mize PE and is being reviewed by NMED. A meeting was held between AV Water, Sauder Miller, and County officials yesterday to go over the flushing program. County issued a media release in our behalf to urge customers over the weekend. We will begin flushing Monday morning August 1.
- 7. Farmington Interconnect:** System is fully connected to Farmington. **Permanent pump station is finished** and has been pumping since about noon July 22, 2016. We will continue to monitor tanks.

NOTE. The order requires completion by July 15. Our attorney Germaine Chappell will file for a formal extension request in writing.

- 8. Water Hauling:** No update See below
- 9. Continuous water service:** Water service has been continuous since June 24 to all customers.
- 10. Regs and BMPs:** All regulatory requirements and Best Management Practices have been followed on all construction.
- 11. Contacts:** The required contacts have been made on all updates and notifications.
- 12. Deviations:** Requirement deviations are being formally requested by our attorney Germaine Chappelle.